



ASTM E-84 Results

Cloth-backed Wood Veneer Sheets

Product	Flame Spread	Smoke Developed Index	Rating
Natural Veneer *	10	0	Class A
Reconstituted Veneer **	20	10	Class A

* Natural Veneer marketed as CraftWood

** Reconstituted Veneer marketed as Friendly Harvest

ASTM E-84 Ratings Explanation

In order to obtain the Flame Spread Classification, results must fall into the ranges below.

Rating	Flame Spread	Smoke Developed Index
Class A	0 - 25	< 450
Class B	30 - 75	< 450
Class C	80 - 200	< 450